

Environmental Health Division

WSLH Sample: 829653001

Report To:
WILBUR PETERS
8780 MORGAN RD
MINOCQUA, WI 54548

Invoice To:
WILBUR PETERS
8780 MORGAN RD
MINOCQUA, WI 54548
Customer ID: 74401162

System Name: LAKELAND SANITARY DIST 1
City: MINOCQUA
Collection Date/Time: 1/20/2026 14:30
Collected By: WILBUR PETERS
County: 44 - Oneida
Source Code: D-Distribution System
Collection Address: 382 USH 51
Location of Sample: BACK SHOP SAMPLE
TAP

Monitor Point ID: D-20
PWS ID#: 74401162
WI Unique Well#:
Entry Point ID:
Date Received: 1/21/2026
Date Reported: 1/22/2026
Sample Type: D-Rout Dist Comp & FU

Field Data

Analyte	Analysis Method	Result	Units	LOD	LOQ
Prep Date: No Prep Step	Analysis Date: 01/21/26 10:18				
Chlorine Total Residual	Field Chlorine Data	0.08	mg/L		

Microbiology

Analyte	Analysis Method	Result	Units	LOD	LOQ
Prep Date: 01/21/26 09:12	Analysis Date: 01/22/26 09:55	Prep Method:	SM9223B		
Total Coliform - Colilert	SM9223B	Absent	/100mL		
E. Coli - Colilert	SM9223B	Absent	/100mL		

Environmental Health Division

WSLH Sample: 829653001

WDNR LAB ID:113133790 NELAP LAB ID:2091

EPA LAB ID:WI00007, WI00008

WI DATCP ID:105-415

List of Abbreviations:

LOD = Level of detection

LOQ = Level of quantification (for PFAS the LOQ = MRL)

ND = None detected. Results are less than the LOD

F next to result = Result is between LOD and LOQ

Z next to result = Result is between 0 (zero) and LOD

if LOD=LOQ, Limits were not statistically derived

Test results for NELAP accredited tests are certified to meet the requirements of the NELAC standards. For a list of accredited analytes see <http://www.slh.wisc.edu/about/compliance/nelac-laboratory-accreditation>

Results, LOD and LOQ values have been adjusted for analytical dilutions and percent moisture where applicable.

Results relate only to the items tested.

This Laboratory Report shall not be reproduced except in full, without written approval of the laboratory.

The water microbiology unit analyzes samples as received and not all samples are tested for preservation before analysis is performed.

Responsible Party

Inorganic Chemistry: Graham Anderson, Supervisor 608-224-6281

Metals: Graham Anderson, Supervisor 608-224-6281

Organics: Erin Mani, Supervisor 608-224-6269

Environmental Toxicology: Dawn Perkins, Supervisor 608-224-6230

Water Microbiology: Martin Collins, Supervisor 608-224-6239

Radiochemistry: Jesse Wouters, Supervisor 608-224-6227

Trace Elements: Christa Dahman, Supervisor 608-224-4320