

LAKELAND SANITARY DISTRICT NO. 1

(715) 356-4454

8780 Morgan Road * Minocqua, WI 54548

(715) 358-8830

Phone

sandist@frontier.com

Fax

NOTICE OF MEETING – REGULAR MEETING

TITLE OF GROUP MEETING: LAKELAND SANITARY DISTRICT NO. 1

PLACE: LAKELAND SANITARY DISTRICT NO. 1 OFFICE
8780 MORGAN RD.
MINOCQUA, WI 54548

DATE: JULY 21, 2026

PURPOSE: REGULAR BOARD MEETING

TIME: 4:00 P.M.

AGENDA:

1. CALL MEETING TO ORDER.
2. APPROVAL OF 7-21-26 AGENDA
3. APPROVAL OF 7-7-26 MEETING MINUTES
4. P. MORROW/ D. RAKERS – MSA WWTP UPGRADE & UPDATES
 - a. CONSIDERATION AND APPROVAL OF MIRON PAY APP
5. APPROVAL OF VERIZON LEASE RENEWAL
6. SIGN CHECKS/PAY BILLS
7. INFORMATION/CORRESPONDENCE

TIME OF POSTING: JULY 16, 2026

NAME AND TITLE OF PERSON
DIRECTING THAT THIS NOTICE
BE POSTED: TOM WIPPERFURTH
PRESIDENT

Upon reasonable notice, efforts will be made to accommodate the needs of the disabled individuals through appropriate aids and service. Contact the Lakeland Sanitary District @ 715-356-4454.

NOTICE OF MEETING.doc

LAKELAND SANITARY DISTRICT NO. 1
REGULAR MEETING
July 21, 2026

Present: T. Wipperfurth, R. LaPlante, M. Killian

Absent:

Others: W. Peters, J. VanSkyhawk, A. Schlieve, P. Morrow – MSA, A. Rakers -- MSA

The meeting was called to order by President T. Wipperfurth on July 21, 2026 at 4:00 P.M. All public notices have been posted to meet with the open meeting law and the building is accessible for the handicapped.

Approval of 7-21-26 Agenda: R. LaPlante made a motion to approve the 7-21-26 agenda. M. Killian seconded the motion. All in favor, motion carried.

Approval of 7-7-26 Regular Meeting Minutes: R. LaPlante made a motion to approve the minutes for the 7-7-26 meeting minutes; T. Wipperfurth seconded the motion. All in favor, motion carried.

Agenda Item #4: P. Morrow, MSA WWTP Upgrade and Updates: July Construction Update: The Engineering team continues to review shop drawings, issue field orders, issue proposal requests, and answer requests for information (RFIs) from the Contractors pertaining to the Contract Documents. The Engineering team has been observing start-ups and recording training sessions for the Owner.

Work has progressed according to schedule since the July 7, 2026 meeting. At the Str. 630 ATAD Complex, the Contracting team has completed a system check out and started control panel testing with Thermal Processing Systems (TPS). Currently, the team is completing clear water testing and functional testing. The Contractor will start feeding sludge to the new ATAD Complex the week of July 27th.

In the Str. 610 Biosolids Processing Building, the Electrical Contractor has continued to run conduit and install electrical equipment. The Mechanical Contractor has continued to install mechanical equipment and HVAC ductwork. The Contracting team is preparing for the ATAD Feed Pumps, Gravity Belt Thickening, and Polymer Feed start-ups in July. The pulsed air mixing system in Tank B of the Str. 600 Sludge Storage Complex has been started-up and Owner training has been completed. The pulsed air mixing system in Tank A is to be installed after the tank is emptied and cleaned in late July. The Contracting team is preparing for further pulsed air mixing and thickener feed pump start-ups in July and August. The temporary dewatering skid northeast of the Str. 610 Biosolids Processing Building has continued operation. The temporary dewatering skid is to be decommissioned and removed from site after sludge processing equipment is started up this week.

Agenda Item #5: Approval of Verizon Lease Agreement: Item tabled as the lease agreement was not ready from Verizon in time for the meeting.

Agenda Item #6: Sign Checks/ Pay Bills

Agenda Item #7: Info/Correspondence: W. Peters informed the board that a WWTP TFO did occur involving the effluent and the UV disinfection going to the Tomahawk River. The DNR has sent a Required Public Notification – Ultraviolet Disinfection System Failure to the District and we will be required to publish a public notice in the newspaper, post notification on the District's website, post notices at public access points and other locations where the public commonly accesses or recreates at the Tomahawk River and also notify the Oneida Public Health Department. The notice needs to be done by July 24, 2026. W. Peters said they may hear feedback from the community about it. Lakeland Sanitary staff is working on fixing the problem as quickly as possible to address the issue and protect the environment and community.

There being no further business, the meeting was adjourned at 4:40 PM, on a motion by M. Killian, seconded by R. LaPlante.

Clerk:

Rick A. LaPlante